

Classification Report

Number	25-004234-PR01 (NW-C01-05-en-01)
Owner	DRUTEX S.A. ul. Leborska 31 77-100 Bytow Poland
Product	Burglar resistant external pedestrian doorset with glass infill and fixed side glass panel
Designation	MB-86N
Details	Manufacturer DRUTEX S.A., Bytow; Material Aluminium, powder coated; Overall dimensions (WxH) 1910 x 2410 mm; Attack side opening and inward face as per EN 12519; lock PK1: Manufacturer Carl Fuhr GmbH&Co. KG, Heiligenhaus; Designation Autosafe 835 Typ 10; lock PK2: KfV Karl Fliether GmbH & Co. KG, Velbert; Designation BS3700; note for both locks auxiliary lock as hook and bolt, acc. to EN 15685:2019, on digit 7 and digit 9: class 4; Profile cylinder: Designation Lucznik-Lockpol MCM C Profil E7; note according to EN 1303: class 6/D; hinge PK1: Manufacturer Simonswerk; Designation Single-axis, 5000056260 Alpro ALC 1453D29-01 KTL; hinge PK2: Manufacturer Wala Sp. Z o.o.; Designation hidden, WU1R; Hinge side security in PK2: Manufacturer Carl Fuhr GmbH & Co. KG; Designation double pin, Multisafe ALU; bonded insulated glass unit: Designation Pennsylvania 5; Manufacturer Guardian; note acc. to EN 356: P4A;

Special features

Result **)

Burglary resistance according to EN 1627:2021-06



Class: RC 2 / RC 2N

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim
08.04.2026

Florian Willer, Dipl.-Ing. (FH)
Head of Testing Department
Security/Safety Testing

Roman Rubensdörffer
Operating Testing Officer
Security/Safety Testing

Basis *)

EN 1627:2021-06

*) and corresponding national versions (e.g. DIN EN)

Test report: 25-004234-PR01 PB-C01-05-en-01

Representation



Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift-Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 022-07861